

Disinfection By-products Continuing Evaluation



Since the required regulatory sampling is only two isolated sites within the District (STA5 and STA7 on the attached maps) the District sampled a number of other sites to determine if the exceedance area was localized or widespread. As can be seen on the attached maps the area of exceedance is localized to the Lower Pine Crest area.

Special Disinfection By-Products Sampling

Sample #	Location	7/23/18		9/10/18(Q3)		LRAA-9/10/18	
		TTHM*	HAA5*	TTHM	HAA5	TTHM	HAA5
4	Idyllwild Elementary School (Elm)	12	6.2	0.56	ND		
5	Near IAA (Tollgate/TG)	45	28	4.1	ND		
3	Higher Grounds (HG)	46	31	2.7	ND		
1	Lower Pine Crest (STA5)	72	44	14	5.6	70.8	43.2
2	Double View (STA7)(Q2)	39	14	12	3.6	33.8	14.1
LRAA Maximum Limit (Avg of 4 Samples)				80	60		

Meets Standards

*Parts per billion (micrograms per milliliter)