



# **IDYLLWILD WATER DISTRICT**

## **2020 CONSUMER CONFIDENCE REPORT**

June 2021

# IDYLLWILD WATER DISTRICT

## 2020 CONSUMER CONFIDENCE REPORT

The enclosed Consumer Confidence Report provides information regarding the quality of water that you received from the Idyllwild Water District (IWD) during 2020. IWD staff work diligently to provide its customers safe, high quality water. We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards.

The District uses Foster Lake to recharge water naturally through percolating water, which maintains the groundwater levels to the surrounding Foster Lake wells. IWD receives water directly from Lilly Creek into Foster Lake. Our other source for Foster Lake is a stream diversion on Strawberry Creek that is pumped across town into the Lake. Unfortunately, the current year (2020) has only produced about 50% of average snow and precipitation.

The Board of Directors and staff at the District are dedicated to preserving our watershed and sustaining our environment, now and into the future. Through cooperation and our customers continually improving efficiency in water use, IWD will create reliability of supply to cushion against extended future drought. Through community cooperation and the implementation of efficiencies, the Board of Directors strives to support the local economy and to ensure sustainable supplies for the future.

*We test the drinking water as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2020 and may include earlier monitoring data.*

**Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.**



Idyllwild Water District mission is to provide reliable water and sewer service in a safe, cost-effective and environmentally sound manner in accordance with the community needs.

Board of Directors

Dr. Charles Schelly,  
President

Peter Szabadi, Vice  
President

Steve Kunkle, Director

Les Gin, Director

Vacant, Director

General Manager

Leo Havener

Chief Financial Officer

Hosny Shouman

Chief Water Operator

Joseph Reyes

Idyllwild Water District  
25945 Hwy. 243  
P.O. Box 397  
Idyllwild, CA 92549  
Phone (951) 659-2143  
Fax (951) 659-9990

Type of water source(s) in use: Groundwater

Name & location of source(s): Water in 2020 was supplied from 10 of the 24 wells owned by IWD.

Drinking Water Source Assessment information: Completed in 2007 and is available for review at IWD office located at 25945 State Hwy. 243, Idyllwild, CA 92549.

Time & place of regularly scheduled Board meetings for public participation:  
Third Wednesday of the month at 6:00 p.m. in the IWD Boardroom located at 25945 State Hwy. 243, Idyllwild, CA 92549.

For more information contact: Leo Havener, General Manager Phone: 951-659-2143

The following tables list all the drinking water contaminants that we detected from testing for the 2020 calendar year or earlier. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The state allows us to monitor for certain contaminants less than once a year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of the data, though representative of the water quality, are more than one year old.

**The sources of drinking water** (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- *Microbial contaminants*, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals that can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides* that may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, agricultural application, and septic systems.
- *Radioactive contaminants* that can be naturally occurring or be the result of oil and gas production and mining activities.

**In order to ensure that tap water is safe to drink**, the U.S. Environmental Protection Agency (U.S. EPA) and the State Water Resources Control Board (State Board) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. State Board regulations also establish limits for contaminants in bottled water that provide the same protection for public health.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Idyllwild Water District is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components.

When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Infants and young children are typically more vulnerable to

lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the U.S. EPA Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>.

**Terms and abbreviations used in the tables are as follows:**

**Public Health Goal (PHG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency.

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**Primary Drinking Water Standard:** MCLs and MRDLs and treatment techniques (TTs) for contaminants that affect health, along with their monitoring and reporting requirements.

**Regulatory Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

**Secondary Maximum Contaminant Level (SMCL):** Non-enforceable guidelines regarding chemicals that may cause cosmetic or aesthetic effects in drinking water.

**N/A:** not applicable

**N.D.:** not detectable at testing limit

**ppm:** parts per million or milligrams per liter

**ppb:** parts per billion or micrograms per liter

**pCi/L:** picocuries per liter (a measure of radiation)

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (1-800-426-4791). Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

***Use Less Water, Spend Less Money***

- Stop Leaks – Check appliances and outside systems such as sprinklers for leaks. Get to know your water meter – it provides important information about consumption and leaks. Common leaks waste 10% of the water used in many homes.
- Replace Old Toilets – Toilet flushing is the top water user in the home. If you haven't replaced your toilet in 10 years or more, you'll benefit from the new high efficiency models. Check the internal flapper for

leaks by adding a little food coloring to the tank. If the colored water shows up in the toilet bowl, it's time to replace the rubber flapper.

- Buy an efficient Clothes Washer - Washers are the second-largest water user in the home. New "Energy Star" certified models use 50% less water and energy per load.
- Visit our website [www.idyllwildwater.com](http://www.idyllwildwater.com)

Some of the above suggestions may save hundreds of dollars per year in water and energy costs. If you need more information, call us at (951) 659-2143.

#### Sampling Results Showing Detection of Lead and Copper (2020)

Lead and Copper (unit of measure)	No. of Samples Collected	90 <sup>th</sup> Percentile Level Detected	No. of Sites Exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	10	5	None	15	0.2	Internal corrosion of household water plumbing systems; erosion of natural deposits
Copper (ppm)	10	0.44	None	1.3	0.3	Internal corrosion of household water plumbing systems; erosion of natural deposits; leaching from wood preservatives

No schools requested lead sampling during 2020.

#### Sampling Results for Sodium and Hardness

Chemical or Constituent (unit of measure)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	2018 - 2020	13.9	7.6 - 22	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	2018 - 2020	44.5	26 - 75	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium

#### Detection of Disinfectant Byproducts

Chemical or Constituent (unit of measure)	Sample Date	Highest Running Annual Average	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Chlorine (ppm)	2020	1.10	0.76	[4.0 (as Cl <sub>2</sub> )]	[4 (as Cl <sub>2</sub> )]	Drinking water disinfectant added for treatment
Total Trihalomethanes (TTHMs) (ppb)	2020	61.5*	12 - 71	80	N/A	By-product of drinking water disinfection
Haloacetic Acids (HAA5) (ppb)	2020	49.3*	5.3 - 77	60	N/A	By-product of drinking water disinfection

\*Highest Locational Running Annual Average

### Detection of Contaminants with a Primary Drinking Water Standard

Chemical or Constituent (unit of measure)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Gross Alpha Activity (pCi/L)	2019 - 2020	2.25	0.0 - 8.0	15	N/A	Erosion of natural deposits
Uranium (pCi/L)	2019 - 2020	2.13	0.0 - 6.4	20	.43	Erosion of natural deposits
Nitrate as N (ppm)	2020	0.10	0.0 - 0.64	10	10	Leaching from natural deposits
Aluminum(ppm)	2018 - 2020	0.07	0.0 - 0.22	1	0.6	Erosion of natural deposits

### Detection of Contaminants with a Secondary Drinking Water Standard

Chemical or Constituent (unit of measure)	Sample Date	Level Detected	Range of Detections	SMC L	PHG (MCLG)	Typical Source of Contaminant
Total Dissolved Solids (ppm)	2018 - 2020	116.2	79 - 180	1000	None	Runoff/leaching of natural deposits
Chloride (ppm)	2018 - 2020	6.5	2.1 - 17	500	None	Runoff/leaching of natural deposits
Sulfate (ppm)	2018 - 2020	2.5	0.65 - 8	500	None	Runoff/leaching of natural deposits
Specific Conductance (us/cm)	2018 - 2020	144.2	59 - 250	1600	None	Substances that form ions when in water
Turbidity (units)	2016 - 2020	3.4	0.0 - 14	5	None	Soil runoff
Aluminum (ppb)	2016 - 2020	71.2	0.0 - 220	200	600	Erosion of natural deposits
Iron (ppb)	2018 - 2020	331.6	0.0 - 1600	300	None	Leaching from natural deposits
Color (units)	2016 - 2020	2.3	0.0 - 25	15	None	Naturally-occurring organic materials

### Detection of Unregulated Contaminants

Chemical or Constituent (reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects Language
Bicarbonate Alkalinity	2018 - 2020	68.9	43 - 100	N/A	N/A
Calcium	2018 - 2020	14.6	8.3 - 23	N/A	N/A
pH	2018 - 2020	7.2	6.5 - 7.5	N/A	N/A
Magnesium	2018 - 2020	2.0	0.0 - 4.8	N/A	N/A



Foster Lake May 2021



IWD crews installing pipe October 2020

IDYLLWILD WATER DISTRICT  
25945 HIGHWAY 243  
P.O. BOX 397  
IDYLLWILD, CA 92549-0397

Presort STD  
US POSTAGE  
**PAID**  
Permit 1  
Temecula CA

**Board of Directors**

Dr. Charles Schelly, President  
Peter Szabadi, Vice President  
Steven Kunkle, Director  
Les Gin, Director  
Vacant, Director



# IDYLLWILD WATER DISTRICT

## 2020 Consumer Confidence Report

June 2021